

Parametric design for soil gas flux system: a low-cost solution for continuous monitoring

Alex Naoki Asato Kobayashi¹, Clément Roques¹, Daniel Hunkeler¹, Edward A. D. Mitchell², Robin Calisti², and Philip Brunner¹

¹Centre d'hydrogéologie et de géothermie (CHYN), Université de Neuchâtel

²Laboratory of Soil Biodiversity, Université de Neuchâtel

^{1,2}Rue Emile-Argand 11, Neuchâtel, Switzerland

Correspondence: Alex Naoki Asato Kobayashi (alex.asato@unine.ch)

Abstract.

Monitoring soil gas fluxes is essential for understanding greenhouse gas dynamics within the critical zone. One commonly used method involves chamber-based methods which enables the quantification of soil gas fluxes on a specific point at the soil-atmosphere interface. However, point measurements often limit the representativeness of the field-scale processes due to the large spatio-temporal variability of climatic, hydrological, pedological, or ecological factors controlling its dynamics. Additionally, commercial chambers often ~~prohibits~~ prohibit deployment over sufficient representative area due to expensive operational and purchase costs.

Although low-cost and open-source designs have recently emerged in the literature, solutions enabling adaptability to field-site characteristics and design validation are still lacking. To address these challenges, we propose here a low-cost, parametric soil gas flux system that can be adapted to logistical and field constraints while allowing high-frequency measurement resolution. ~~Alongside the~~ Along with open-design hardware, we ~~also~~ developed software to ~~facilitate automatic data acquisition~~ automate data collection and processing. ~~We conducted laboratory investigations to evaluate~~ Laboratory tests, including static and transient experiments, assessed both the sensor and ~~chamber design integration~~ chamber design integration. Our results show strong agreement between the low-cost and commercial gas analyzers in static conditions with CO_2 levels up to 500 ppm above background. During transient tests, we successfully replicated CO_2 concentration increases using both systems, with comparable response time between eflux and measurement from the sensors. Thus, we ~~can~~ were able to address the data ~~assurance from~~ reliability from the low-cost ~~systems even with different parametric configurations~~. ~~Finally~~ setup, despite different parameters. Ultimately, our approach ~~demonstrate~~ demonstrates that low-cost solutions ~~enable the democratization of these systems by having a framework that can be adaptable for different~~ can democratize these systems through a flexible framework suitable for various study sites.

1 Introduction

Anthropogenic emissions and removal of greenhouse gases (GHG) in agricultural, forestry, and other land uses are driven by biological and physical processes, which can be determined by ecosystem components such as biomass, dead organic matter,

soils, and livestock (IPCC, 2006, 2019, 2021). Most forms of GHG emission through the soils are via microorganisms, root
25 respiration, and chemical processes. Several environmental factors influence the dynamic of CO_2 fluxes, methanogenesis and
nitrification, and denitrification, with the main ones being temperature, soil water content, nutrient availability, and pH (Oertel
et al., 2016; Smith et al., 2018).

Several soil gas flux monitoring technologies exist, with two main approaches being widely used in environmental science:
the Eddy Covariance method (EC) and the chamber-based method. The Eddy Covariance method uses a high-frequency
30 anemometer and gas analyzer (around 20 Hz) to calculate the net flux for water vapor or CO_2 , CH_4 or N_2O (Aubinet et al.,
2012). From the turbulent winds, this direct method measures the covariance from the eddies and the trace gases it carries.
Despite this method contributing largely to the understanding of the global change biology (Baldocchi, 2020; Baldocchi et al.,
2001), it is not a substitute for the use of chamber-based methods because it overlooks small-scale variability of trace gas fluxes
(Eugster and Merbold, 2015; Baldocchi, 2014). Furthermore special care must be taken regarding flux footprints in highly
35 heterogeneous landscapes (Chu et al., 2021), despite continuous measurements from EC, significant uncertainties remain in
measuring the net exchange of GHG (Eugster and Merbold, 2015).

Meanwhile, chamber-based methods are essential to understanding soil gas flux point variability that is affected by topography,
vegetation, soil types, and hydrology. These chambers can be static, dynamic, manually, or semi-autonomously operated. While
the manual chamber approach has been widely used because it only requires one set of chamber and gas analyzer, it is also
40 not capable to performing measurements without an operator, thus it can be hard logistically to have high temporal resolutions
with this approach. In contrast, semi-autonomous systems are particular interesting because it can achieve a high temporal
resolution in less accessible places. However, the chamber's reduced scale compared to EC comes with several challenges
regarding possible measurement artifacts. Maier et al. (2022) aggregated the experience of different groups to define some
"best practices" when measuring soil gas flux. The disposition of chambers in a study site is critical and requires in depth
45 understanding of the ecosystem and a clear definition of the goal of a project, e.g. the goal can be to test the effect of a field
manipulation on an "average" representative microsite replicated over the field site. Depending on how it is performed, there
is the potential of underrepresenting the spatial variability in ecosystems with hotspots or high flux events (Leon et al., 2014;
Jenerette et al., 2008), especially when the cost of the commercially available chambers and gas analyzers is often prohibitively
expensive for some project budgets to distribute several chambers throughout a study site properly.

50 Advancements in low-cost sensors have improved their affordability and accuracy, creating new opportunities to explore
these alternatives for measuring soil gas flux. Some alternatives of manual respiration chambers (Zawilski and Bustillo, 2024;
MacAgga et al., 2024) or more autonomous systems (Gagnon et al., 2016; Forbes et al., 2023) have been developed to meet the
demand for near-continuous monitoring. Their validation is often made using only the sensor's static accuracy. i.e measuring a
given concentration of a standard gas, or duplicate the measurements in the field with a commercial sensor installed in parallel.
55 However, in this case it remains challenging to compare the results due to bias in the sampling footprint. Additionally, it is
well-established that chamber and system design can significantly reduce flux errors when appropriately tailored to the physical
characteristics of a given soil (Venterea and Baker, 2008). We identified a lack of parametrized designs that allow the chambers

to be produced to fit each study site’s conditions and a lack of more reproducible laboratory methodologies that try to simulate soil gas flux signals regarding the chamber methods constraints.

Our main objective is to present a low-cost sensor system for soil gas flux, along with a parametrized chamber design that can be adapted to the specific conditions of any study site. Additionally, we propose a laboratory methodology that allows users to test their designs by implementing a transient experiment. This approach enables users to evaluate the dynamic response time of dCO_2/dt in a controlled environment, ensuring the reliability and accuracy of soil gas flux systems before field deployment.

2 Material and Methods

This study aimed to increase the spatiotemporal representativeness of soil gas flux measurements, enabling the capture near-continuous soil respiration and net ecosystem exchange (NEE) at a given study site. To achieve this, we developed an open-design, low-cost parametric soil gas flux system and proposed a novel laboratory methodology for testing its performance.

2.1 Soil gas flux sensor system: Open-design

The designed soil gas flux sensor system consists of (i) a parametric soil gas flux chamber, (ii) integrated sensor components, and (iii) an integrated controller PCB (Figure 1).




Figure 1. Schematic representation of low-cost CO_2 soil gas flux system indicating the chamber components with sensor box PCB and fan components and main box with controller PCB.

2.1.1 Parametric soil gas flux chamber

The main design philosophy for the soil gas flux chamber was the parametrization of the chamber’s dimensions. Parametrizing the chamber dimensions is crucial for accurately calculating soil gas flux, as different volume-to-surface area ratios significantly influence the evolution of CO_2 concentration within the chamber over time. Some additional implications from the change in chamber dimensions are the air mixing in the chamber when measuring, the optimal range of CO_2 concentration inside the chamber, the minimal detectable flux (section 2.1.3) that the system can calculate, and the area-perimeter ratio to increase the representativeness for a given measurement point.

Thus, two critical parameters can be adapted: chamber diameter and height. These variables directly affect the chamber’s volume and influence the rate of gas accumulation during measurements. The diameter determines the area over which gas is sampled. ~~Parametrization~~ The parametrization of the chamber ~~design according to~~ is field-specific, starting with the expected range of soil gas flux ~~and~~ sensor characteristics, vegetation, ~~which are further constrained by vegetation~~ and material availability (Figure 2)~~improves the adaptability of the instrument to specific field conditions.~~




Figure 2. Parametrized chamber design based on chamber’s constraints such as soil gas flux range, sensor characteristics, vegetation type and user’s material availability

2.1.2 Electronics: sensors and microcontroller

The electronics are divided into two parts: (i) integrated sensor components and (ii) integrated controller PCB. The integrated sensor components is located in the soil gas flux chamber, where the measurement is happening, while the main section is located inside an encasing with the battery and any other main section from other chambers (Figure 1). Each section is in its

weather-protected box, and the microcontroller communicates with the sensor section via I^2C protocol. This communication protocol is digital, and it uses a serial data line (SDA) and a serial clock line (SCL).

Since our objective is to have a system suitable for continuous measurements, the microcontroller has a sequence of events divided into four phases: (i) closing chamber, (ii) measurement, (iii) opening chamber, and (iv) standby. The closing chamber phase activates the motor driver to close the linear actuator and activates all sensors to start their measurement. After the chamber is closed, the measurement phase starts logging the data from all sensors and the fan begins to mix the air inside the chamber. All data from the measured sensors are logged using the micro-SD module, which also keeps the clock time using the real-time clock module (RTC). After the configured measurement period is finished, the opening chamber phase stops the measurements from the sensors and fan, and then the chamber is opened. Finally, the standby phase deactivates all sensors and waits for the user-defined waiting period to finish.

For debugging purposes, we configured the microcontroller to identify, log, and restart the system to its original settings in case of unexpected error or shutdown. This ensures that the user can identify the cause of an error and fix it for future operations.

All sensors and main components are found at the table 1. In order to estimate soil gas flux, it is necessary the CO_2 gas concentration, atmospheric pressure, temperature and humidity sensor. Among those sensors, the cost magnitude difference from the commercial sensor can reach a thousand fold higher compared with the low-cost sensors system. Also, the PCB design and schematics are found at the repository (Kobayashi, 2025).

Component	Manufacturer	Description
K30 FR	Senseair	CO_2 concentration sensor
BMP280	BOSCH	Atmospheric pressure and temperature sensor
SI7021	Silicon Laboratories	Humidity and temperature sensor
Raspberry Pi Pico W	Raspberry Pi Foundation	Microcontroller
TB6612FNG	Toshiba Semiconductor	Motor driver
DS1307	Dallas Semiconductor	RTC
CD74HC4050	Texas Instruments	SD driver

Table 1. List of electronics components

2.1.3 Minimal detectable flux

After considering the chamber design and sensors, we can start integrating both, and the minimal detectable flux, which was proposed by Christiansen et al. (2015), provides what is the expected lower limit for the soil gas flux rates that can be detected. The minimal detectable flux (MDF) considers different characteristics, such as the analytical accuracy of the sensor, the chamber's volume and surface area, and the total chamber closure time. Nickerson further developed equation 1 for instruments that have a sampling time with a higher frequency (e.g. 1 Hz).

$$110 \quad \text{MDF} = \left(\frac{\frac{A_a}{t_c \left(\frac{t_c}{p_s} \right)}}{\frac{A_a}{t_c \sqrt{\left(\frac{t_c}{p_s} \right)}}} \right) \left(\frac{VP}{SRT} \right) \quad (1)$$

Where A_a [ppb] is the analytical accuracy of the instrument, t_c [s] is the closure time of the chamber, V [m^3] is the chamber volume, P [Pa] is the atmospheric pressure, S [m^2] is the chamber surface area, R [$m^3 \text{ Pa } K^{-1} \text{ mol}^{-1}$] is the ideal gas constant, T [K] is the ambient temperature, and p_s [s] is the sampling periodicity.

2.2 Laboratory experiment

115 We performed two laboratory experiments: the first was designed to check the sensor accuracy by imposing a known CO_2 concentration, further mentioned as a static CO_2 concentration experiment (section 2.2.1). The second, aiming at evaluating the sensor's performance in measuring CO_2 changes over time in the chamber, which ultimately is used to estimate the corresponding flux, is further referred to as transient CO_2 experiment (section 2.2.2).

We used bags containing standard CO_2 concentrations for both the static and advection-driven simulated soil gas flux
120 experiments. To prepare the standard bags, we used a 5 liters Tedlar sampling bag with dual stainless steel fittings, where we mixed a given volume of a 99.9% concentration of CO_2 gas with atmospheric air.

2.2.1 Static experiment

The static CO_2 concentration test checks the individual sensor's accuracy of the low-cost sensor against the commercial gas analyzer (LICOR LI-7810) without considering the overall chamber. To ensure both sensors are exposed to the same
125 concentration of gases, the standard CO_2 gas was injected directly through the LI-7810 sensor and then routed to the inlet of the low-cost sensor (K30). In addition, we ensured that the internal clock of both systems was synchronized. Using this approach, we logged the data continuously while the standard CO_2 bag was connected to the inlet of the LI-7810 sensor. Thus, we logged 1502 points from the low-cost sensor and LI-7810 during 12 different standard CO_2 gas bag concentration, ranging from 200 ppm until 1100 ppm above the CO_2 background concentration.

130 2.2.2 Transient CO_2 experiment: dynamic response on the system

The transient CO_2 experiment aim to better understand the systems' temporal CO_2 concentration evolution inside an accumulation chamber given a known CO_2 standard gas concentration. The first step for this experiment was to measure the concentration of the imposed CO_2 gas bag standard. This was done by measuring with the LI-7810 the gas bag concentration. For this experiment, we targeted a concentration of 900ppm +/-10%, for which we had a total of 8 CO_2 gas bags. The second step
135 consists of measuring the ~~CO2~~- CO_2 accumulation in the ~~chambers of both LICOR~~ commercial chamber (LICOR 8200-01S) with the gas analyzer (LI-7810~~with 8200-01S)~~ and our design systems. This is done by closing the respective chambers and

measuring the evolution of CO_2 concentration until the gas bag is empty (Figure 3). Finally, we open the low-cost parametric chamber to return to the atmospheric background CO_2 concentration.




Figure 3. Schematic laboratory experiment using the transient CO_2 experiment, from background atmospheric CO_2 concentration to the increase of concentration after the chamber is closed then the opening of chamber back to the atmosphere and an additional step for chamber leak for the low-cost system. The black line represents our reference (8200-01S and LI-7810) and the red line represents our low-cost system.

The evaluation procedure for both systems' transient CO_2 experiment utilizes a numerical model estimation and compares them with the measured data. The assumptions for this model are constant pressure, temperature, and humidity throughout the experiment. With constant pressure, a leakage term from both systems is expected and is considered for our transient CO_2 experiment. So, the influx equals the outflux (leakage term), or the total volume is conserved during the experiment period. From this transient experiment, we modeled the chamber CO_2 mass, thus following the equation 2.

$$\text{Chamber Mass}_{CO_2}(t) = \text{Chamber Mass}_{CO_2}(t=0) + \dot{m}_{CO_2} - \dot{o}_{CO_2} \quad (2)$$

Which, \dot{m}_{CO_2} is the standard CO_2 mass gas input to the chamber and \dot{o}_{CO_2} is the leakage of CO_2 from the chamber and $\text{Chamber Mass}_{CO_2}$ is the CO_2 mass in the chamber.

Through modeling, we can compare the expected CO_2 curve evolution through time with the measured data, but to compare the system between each other, it is necessary to perform an adimensional analysis. There are differences between our reference (LI-7810 and 8200-01S) and low-cost sensor systems regarding the setup, such as chamber volume, initial CO_2 concentration,

150 standard CO_2 concentration gas bag, and injection flux rate. And to compare both system that utilized different setups, we normalized the time (Equation 3) and the concentration (Equation 4).

$$\hat{t} = \frac{t}{\frac{V_{chamber}}{Q}} \quad (3)$$

Where, \hat{t} is the dimensionless time, t is time, $V_{chamber}$ is the chamber volume and Q is the standard CO_2 gas bag of CO_2 injection flux rate.

$$155 \quad \hat{C} = \frac{C - C_0}{C_{inj} - C_0} \quad (4)$$

Where, \hat{C} is the dimensionless CO_2 concentration, C is the CO_2 concentration at a given time, C_0 is the initial CO_2 concentration before the injection start and C_{inj} is the CO_2 concentration from the standard gas bag.

2.3 Field experiment

To evaluate the reliability and performance of our newly developed system under real-world conditions, we deployed it in the
 160 field, focusing on its ability to capture soil gas flux dynamics accurately and consistently in a natural setting. The experimental site is located on the elevated Swiss Plateau in the city of Kerzers, in the canton of Fribourg, Switzerland. The region's climate is temperate, with annual precipitation between 800 and 1400 mm and an annual temperature of 8 to 12°C and the site's elevation is approximately 432 m.a.s.l. and this regions is considered the most productive region in Switzerland for vegetable production. However, the agriculture situation in this region has become critical because of its highly organic soil
 165 type characteristics (peaty soil). And with the drainage requirements for agriculture, the carbon storage has been depleted by the exposition from the drainage areas, causing subsidence and significant emissions of CO_2 (Egli et al., 2021; Roeoesli and Egli, 2024). Thus, to promote sustainable management of these cultivated peaty soils, monitoring those emissions is required to evaluate the efficacy of the management of these soils (Ferré et al., 2019).

There are two main calculation models used for estimate soil gas flux is the linear and the non-linear model. We calculated
 170 the CO_2 soil gas flux using the H-M model (Pedersen et al., 2010), which uses an exponential equation (equation 5) to fit the CO_2 concentration data and it is considered more accurate than the linear model (Baneschi et al., 2023). After fitting the measured data to the equation, we can extract the fitted variables and then calculate the $\frac{dC}{dt}$ (equation 6).

$$C_c(t) = C_x + (C_0 - C_x)e^{-\alpha(t-t_0)} \quad (5)$$

where C_0 [ppm] is the initial concentration of CO_2 before the chamber was closed, C_x [ppm] is the soil gas concentration
 175 of CO_2 in the soil, α [$m \ s^{-1}$] is the CO_2 soil gas conductivity, C_c [ppm] in the function of time is the chamber concentration, and t [s] is time since the chamber is closed.

$$\frac{dC}{dt} = \alpha(C_x - C_0)e^{-\alpha(t-t_0)} \quad (6)$$

And finally, the soil gas flux can be calculated using the following equation 7.

$$F_{CO_2} = \frac{10VP_0(1 - W_0/1000)\frac{dC}{dt}}{RA(T_0 + 273.15)} \quad (7)$$

180 $V [cm^{-3}]$ is the chamber volume, $A [cm^{-2}]$ is the area of the corresponding chamber ring, $P_0 [kPa]$ is the initial pressure of the chamber, $W_0 [mmol mol^{-1}]$ is the water humidity vapor, and $T_0 [^{\circ}C]$ is the initial chamber temperature.

~~With the prior knowledge of the~~ Past field campaigns gave us some insights about the minimal soil respiration for this study site of around $2000 mmols m^{-2} s^{-1}$, our low-cost soil gas flux sensor system setup ~~consistent~~ consists of continuous measurements of 200 seconds, with a total of 4 repetitions and a standby time of 25 minutes. The goal was to assess the in-situ
185 capacity of continuous measurement in the field environment while measuring the diurnal cycle of the CO_2 soil respiration.

3 Results

3.1 Parametric chamber design

The open-source parametric chamber design, integrated sensor PCB, integrated controller PCB, and software can be found in the public repository (Kobayashi, 2025). In this repository, we split into chamber parametric design for the assembly and
190 software for control and operation of the whole system. The parametric design starts when the user has to define an initial expected soil gas flux CO_2 range to optimize the chamber's dimension for this minimal soil gas flux, and to calculate the expected range of concentration of CO_2 for any given measurement time. Additionally, we take the sensor's manufacturer accuracy, the list of possible materials from the user, the vegetation's expected height if measuring the net ecosystem exchange (NEE), and the user's measuring time to consider the minimal dimensions for the chamber. This information from the user is
195 then utilized to define a list of options that best fit the user's study site based on the minimal detectable flux ~~but also trying~~, try to maximize the base area-perimeter ratio (Maier et al., 2022) while trying to maintain the chamber's concentration optimal range of CO_2 concentration.

For our choice in the design for our specific study site, the low-cost CO_2 sensor has an accuracy of 30 ppm, and we initially defined a measurement time of 150 seconds which a chamber height of 50 cm would get us a minimal detectable flux of
200 $350 nmols m^{-2} s^{-1}$ (Figure 4). ~~Considering a chamber height of 50 cm was the maximum for our desired minimal detectable flux, we choose to reduce the height to~~ Inversely, the maximum expected soil gas flux constrains the chamber height so that the CO_2 gas concentration inside the chamber stays less than $\Delta 500$ ppm above the background concentration, thus we choose a height of 20 cm with a the chamber diameter of 20 cm ~~due to material availability~~ also to fit material availability constraints. With this diameter, the ratio area-perimeter is 5 cm, which is considered acceptable regarding the relative disturbance from the
205 soil ring edge along the base (Healy et al.; Maier et al., 2022). Also, this reduction in chamber height implied that we improved

the minimal detectable flux to around $120 \text{ nmols m}^{-2} \text{ s}^{-1}$ if we later decide to switch from soil respiration to NEE, or we also could reduce the measuring time and maintain a higher minimal detectable flux (Figure 4).




Figure 4. Matrix of minimum detectable flux given chamber height and measurement time, where we change our chamber design and measurement time to adjust the minimum detectable flux

3.2 Laboratory analysis: static test

For the static CO_2 concentration test, we considered the relative difference between the background CO_2 concentration recorded by each sensor and the concentration of CO_2 measured from the standard CO_2 bag, labeled ΔCO_2 . Our approach showed a good linear correlation between the two sensors ($y = 1.005x$) for $\Delta CO_2 < 600$ ppm measured with the LI-7810 (Figure 5). For $\Delta CO_2 > 600$ ppm, the regression slightly changed with lower values measured by our low-cost sensor with respect to the commercial LI-7810. Considering this higher concentration range, the linear regression tended to $y = 0.946x$ (Figure 5). Thus, the low-cost sensor underestimates in comparison to the LI-7810 when introducing a standard CO_2 gas concentration of > 600 ppm above the background concentration.

3.3 Laboratory analysis: transient CO_2 experiment

Our results from the laboratory analysis based on the transient CO_2 experiment show how their absolute concentrations differ from the reference to the low-cost approach. The ΔCO_2 concentration for the reference ranges from 0 ppm to 90 ppm, and for the low-cost approach, the range is from 0 ppm to 190 ppm; in addition, the measuring time difference between the reference is 120 seconds, while the low-cost sensor is about 180 seconds.

To allow us to compare two different setups (chamber volume and initial conditions), we utilized the adimensional concentration and time to normalize the inputs from each system. The normalization can be observed in Figure 6, which shows that the




Figure 5. Static CO_2 concentration comparison between LI-7810 and low-cost sensor K30 relative to their background concentration, where it shows the linear relationship for the whole range ($y = 0.946x$) and zoom in to the range between 150 and 500 ppm ($y = 1.005x$).

measured data fits closest with the modeled curve for both the reference and low-cost system. By checking their respective residuals, the measured data maintained stability over the entire measurement period after a slight increase at the beginning. These results show that both systems were able to mix the air inside the chamber properly when measuring the CO_2 concentration and confirm the air tightness of the system that injects the standard gas.

The initial offset on the residuals (Figure 6) from both reference and low-cost systems indicated a response lag, which comes from the initial injection of the standard CO_2 gas and mixing time in the chamber. This offset from the reference was lower when compared to the low-cost sensor, indicating that the lag from the low-cost system was higher than our reference. Converting back to time, the lag from the commercial system was about 5 seconds, while the low-cost system was about 20 seconds.

3.4 Field deployment

Our field experiment was performed from June 12th to 14th of 2024, and a total of 314 CO_2 soil gas flux measurements were made during this period. This brief snapshot of CO_2 concentration showed the diurnal cycle (Figure 7a). The initial concentration of CO_2 changed from a range of 430 ppm during the daytime to 600 to 800 ppm during the nighttime. For the CO_2 soil gas flux (Figure 7b), values of around $4.5 \mu mol m^{-2} s^{-1}$ was measured with a peak of around 16 : 00 for both days, but during the nighttime, the value fluctuated around $2 \mu mol m^{-2} s^{-1}$ and with a variance higher (0.14) than the daytime (0.02). During this experiment there was no precipitation, thus we can see the slight decrease in top soil water content (Figure 7), where during the night the soil water content decrease is lower than compared during the day. Also, we can see the soil temperature diurnal cycle, which ranged from $15^\circ C$ during the night to around $18^\circ C$ at around 16 : 00.




Figure 6. Dimensionless concentration plotted against dimensionless time, showing residuals between the measured concentration and the expected modeled curve. Panel (a) displays results from the LI-7810 sensor, while panel (b) shows results from the low-cost sensor system.

4 Discussion

4.1 Overall challenges and opportunities in soil gas flux measurement

Measuring soil gas flux is inherently challenging due to the complex interactions between the soil, vegetation, and atmosphere. The combination of accumulation chambers and Eddy Covariance systems has proven valuable applications (Basri et al., 2024; Alice Courtois et al., 2019), but the high costs of commercial dynamic chambers limit their scalability and accessibility for spatiotemporal variability analysis. In this context, low-cost sensor systems (Gagnon et al., 2016; Forbes et al., 2023; MacAgga et al., 2024) offer a promising alternative or complement, providing an affordable and scalable solution for soil gas flux monitoring.

Custom chambers have the flexibility to be parametrized to adapt their design to different study sites and expected flux conditions beyond the specific conditions for which they were originally developed. However, their development represent an investment and various expertise are required for their initial design and testing. In addition, while custom chambers and low-cost sensors enable an increase in the number of measurement points, they also transfer the burden of ensuring data quality to the user, who must validate the performance of these newly designed low-cost systems.




Figure 7. Field measurement of the low-cost soil gas flux system for two day period where it shows (a) initial concentration of CO_2 at each measurement, (b) the soil gas flux of CO_2 with median of the moving window of 60 minutes, (c) the top soil water content and (d) the top soil temperature.

These challenges shaped our study's objective: to develop a parametric and open-source design adaptable to diverse study site conditions, maintain the low-cost system approach, and propose a transient CO_2 experiment method to evaluate the efficiency of custom chambers and ensure seamless integration between chamber and sensor. Such integrated solution from the chamber and sensor implies the necessity of having a more holistic approach that is capable of evaluating the performance of an entire system instead of a single component.

4.2 Performance validation: laboratory static and transient experiment and field application

For the parametric chamber design and overall low-cost soil gas flux system, we built up on some general guidelines based on experiences from several study sites (Maier et al., 2022). Previous studies developed low-cost solutions for semi-continuous measurements of soil respiration (Gagnon et al., 2016; Forbes et al., 2023).

In the proposed solution, we allow the users to adapt the chamber's dimensions to fit the study site requirements. Of course, the choice of the material of the chamber is flexible. We used here a high light and UV transmission materials to monitor Net Ecosystem Exchange (NEE). Of course, the material needs to be adapted if one is aiming at monitoring only soil respiration, by using opaque materials like PVC. Additionally, in our repository, we made available a open-source software responsible for controlling the systems procedures and the design of all components necessary to integrate the chamber to the sensor. This includes the PCB designs that can easily be modified and fabricated to fit other sensors.

After the chamber design was set, we focused on the sensor capability to measure the evolution of CO_2 concentration inside the chamber. Initially, the static test we performed between our proposed choice of low-cost sensor and reference showed a linear correlation in the concentration range 400 – 800 ppm, which agrees with other studies that utilized the same sensor (K30) (MacAgga et al., 2024; Gagnon et al., 2016), but we found that this relationship deteriorates around 1000 ppm, at which the low-cost sensor ended up underestimating. For the application to our field site, with a two-day snapshot of measurements, the observed range of CO_2 concentrations remained below 1000 ppm, so this limitation did not pose an issue in our case. However, to address scenarios where higher CO_2 concentrations might occur, one potential solution would be to increase the chamber height using the parametric design solution. This adjustment would reduce the final CO_2 concentration by allowing for a larger chamber volume, thereby mitigating potential sensor limitations at higher concentrations. Another approach is to reduce the total measurement time at night, which is the simplest option, provided that the measurement duration remains sufficient to ensure an accurate flux calculation.

While most studies evaluated the sensor's static CO_2 accuracy (MacAgga et al., 2024; Gagnon et al., 2016; Zawilski and Bustillo, 2024), our experiment allowed us to also analyze the integration of the sensor within the chamber. It evaluated the efficiency of the air mixing and the response lags between the input and measurement from both systems. ~~We, which could only be compared through dimensional analysis. With our chamber dimensions and fan control settings, we~~ found the chamber design and low-cost sensor to be very satisfactory with similar results compare to our commercial LICOR reference. ~~Such a comparison between systems with different initial chamber conditions was only possible to be done with the use of dimensional analysis~~ Although the low-cost sensor has a slower response time than the commercial sensor, both lag times can be used as inputs for soil gas flux calculation as the unmixed phase (deadband), allowing initial data to be filtered out before calculating flux.

In the field, it is expected that the soil gas flux happens mostly via diffusion instead of advection as imposed in the experiment. But for our case, this difference in mechanisms did not influence the results of our sensor/design validation. Bringing our low-cost system to the field for 2-day ~~long monitoring showed the robustness of the design to monitoring~~ a snapshot its usage in real case applications with a chamber height of 20 cm and a chamber diameter of 20 cm. We could first monitor the variations of ambient CO_2 concentrations by considering the first value reported by the sensor after chamber closing. This minimum ambient values of CO_2 concentration during the daytime had similar values as the ones reported by the Atmosphere Thematic Centre (Jungfrauoch) (Emmenegger et al., 2025). We also observed an increase in the initial CO_2 concentration during the nighttime. This increase was likely to be linked with the atmosphere's boundary layer's higher stability when compared with daytime, which results in its stratification near the surface. The boundary layer's stratification generally has a higher concentration of CO_2 near the surface, which then reduces the diffusion rate through the soil to the atmosphere, thus reducing the soil respiration during the nighttime (Lai et al., 2012; Schneider et al., 2009).

This stratification has possible consequences for the low-cost sensor as it imposes an initial concentration higher during the nighttime compared to the daytime (Figure 7a). This implies that higher concentrations are expected during accumulation during the night, potentially leading toward ranges with higher uncertainties (Figure 5). To prevent these uncertainties, the operators need to consider these values during the design of the chamber and measuring times. Görres et al. (2016) suggested

shorter chamber heights (< 20 cm) and chamber systems that avoid abrupt movements to maintain the stable atmospheric layer.
305 To account for these disturbances for the low-cost system, one could reduce or completely turn off the fan inside the chamber during the nighttime to avoid those artifacts while increasing the measurement period to compensate for this decrease in air mixing rate, and we could also slow down the closing speed for our chamber to avoid breaking the atmospheric stability.

4.3 Final considerations

Finally, this study did not focus on the flux calculation schema for calculating the soil gas flux after the measurement of CO_2 .
310 ~~and. Instead~~ we only utilized a non-linear method (H-M method) for its calculation. ~~There are other available methods, such as linear fit, to determine the dCO_2/dt , when associated with a shorter measuring time~~ Other methods, like linear fitting, are simple to apply and can be useful ~~to avoid lateral fluxes bias (Johannesson et al., 2024; Kandel et al., 2016). Still, the system design is closely link with the performance of a any particular flux calculation schema. It is important now to identify the best methodology available to process this low-cost systems are able to produce while estimating the uncertainties associated.~~
315 considering that is more precise but less accurate (Venterea et al., 2020). And some progress has been made with ideas of balancing the bias and uncertainty from linear and non-linear methods (Hüppi et al., 2018), ~~while understanding along with an understanding of~~ the importance of identifying the optimal time intervals for these flux estimative (Baneschi et al., 2023; Johannesson et al., 2024). Still, the system design is closely linked with the performance of any particular flux calculation schema. While characterization of analytical uncertainty for soil gas flux (Cowan et al., 2025) is a step forward for determining
320 the theoretical limits of the precision of flux measurements for different chamber systems, it uses the frequentist approach combined with the linear method. Thus, a flux calculation schema that quantifies uncertainty for non-linear models which accounts for sensor's characteristics are still needed to be investigated to better understand low-cost system's limitations.

5 Conclusions

The development and implementation of low-cost soil gas flux systems present significant opportunities for advancing the
325 monitoring of hydrological and ecological processes. By enabling ~~high-frequency-high~~ high spatiotemporal measurements, these systems open new avenues for disentangling the coupled processes that drive soil gas fluxes, such as the impacts of extreme rainfall events, sudden changes in water table height, and soil management practices like mechanization. It also facilitates the integration into a multi-modal spatial monitoring system, such as with eddy covariance systems that could improve the knowledge of complex settings such as peatlands renaturation goals.

330 Our approach leverages the flexibility of low-cost sensors and proposes solutions for open design, parametrization and software for operating the system. In addition, we proposed a transient experiment to evaluate and compare the performance of soil gas flux systems in controlled conditions. This methodology enhances quality assurance and helps validate the integration of sensors within the chamber design, offering a comprehensive workflow for system optimization. The proposed design has the potential to significantly expand the monitoring of soil gas fluxes. It brings perspectives for broad applicability that can

335 meet the needs of various applications and field conditions for improved understanding of the dynamics of soil-atmosphere interactions and their responses to environmental changes.

. The code and the parametric chamber design are available in the Github (<https://github.com/alexnaoki/SoilGasFlux>) (Kobayashi, 2025).

. AK: conceptualization, instrumentation design, code programming, laboratory experiment, formal analysis, methodology, validation, writing-original draft and editing. CR: conceptualization, formal analysis, methodology, validation, writing-original draft and editing. DK: 340 formal analysis, methodology, writing-review, editing and funding. PB: formal analysis, methodology, conceptualization, writing-review, editing and funding. EM: formal analysis, validation, writing-review and editing. RC: validation, writing-review and editing.

. The authors declare that they have no known competing financial interests or personal relationships that could have appeared to influence the work reported in this paper.

. We would like to thank Ana Tanaka, Saeed Mhanna, Francesco Scattolini, Laurent Marguet and Roberto Costa for their valuable comments 345 and advice.

References

- Alice Courtois, E., Stahl, C., Burban, B., Van Den Berge, J., Berveiller, D., Bréchet, L., Larned Soong, J., Arriga, N., Peñuelas, J., and August Janssens, I.: Automatic high-frequency measurements of full soil greenhouse gas fluxes in a tropical forest, *Biogeosciences*, 16, 785–796, <https://doi.org/10.5194/bg-16-785-2019>, 2019.
- 350 Aubinet, M., Vesala, T., and Papale, D.: *Eddy Covariance*, Springer Netherlands, Dordrecht, 1^o edn., ISBN 978-94-007-2350-4, <https://doi.org/10.1007/978-94-007-2351-1>, 2012.
- Baldocchi, D.: Measuring fluxes of trace gases and energy between ecosystems and the atmosphere – the state and future of the eddy covariance method, pp. 3600–3609, <https://doi.org/10.1111/gcb.12649>, 2014.
- Baldocchi, D., Falge, E., Gu, L., Olson, R., Hollinger, D., Running, S., Anthoni, P., Bernhofer, C., Davis, K., Evans, R., Fuentes, J., Goldstein, A., Katul, G., Law, J. B., Lee, X., Malhi, Y., Meyers, T., Munger, W., Oechel, W., Paw, K. T., Pilegaard, K., Schmid, H. P., Valentini, R., Verma, S., Vesala, T., Wilson, K., Wofsy, S., and Hall, H.: FLUXNET: A New Tool to Study the Temporal and Spatial Variability of Ecosystem-Scale Carbon Dioxide, Water Vapor, and Energy Flux Densities, *Bulletin of the American Meteorological Society*, 82, 2415–2434, [https://doi.org/10.1175/1520-0477\(2001\)082](https://doi.org/10.1175/1520-0477(2001)082), 2001.
- Baldocchi, D. D.: How eddy covariance flux measurements have contributed to our understanding of Global Change Biology, *Global Change Biology*, 26, 242–260, <https://doi.org/10.1111/gcb.14807>, 2020.
- 360 Baneschi, I., Raco, B., Magnani, M., Giamberini, M., Lelli, M., Mosca, P., Provenzale, A., Coppo, L., and Guidi, M.: Non-steady-state closed dynamic chamber to measure soil CO₂ respiration: A protocol to reduce uncertainty, *Frontiers in Environmental Science*, 10, <https://doi.org/10.3389/fenvs.2022.1048948>, 2023.
- Basri, M. H. A., McCalmont, J., Kho, L. K., Hartley, I. P., Teh, Y. A., Rumpang, E., Signori-Müller, C., and Hill, T.: Reducing bias on soil surface CO₂ flux emission measurements: Case study on a mature oil palm (*Elaeis guineensis*) plantation on tropical peatland in Southeast Asia, *Agricultural and Forest Meteorology*, 350, <https://doi.org/10.1016/j.agrformet.2024.110002>, 2024.
- 365 Christiansen, J. R., Outhwaite, J., and Smukler, S. M.: Comparison of CO₂, CH₄ and N₂O soil-atmosphere exchange measured in static chambers with cavity ring-down spectroscopy and gas chromatography, *Agricultural and Forest Meteorology*, 211–212, 48–57, <https://doi.org/10.1016/j.agrformet.2015.06.004>, 2015.
- 370 Chu, H., Luo, X., Ouyang, Z., Chan, W. S., Dengel, S., Biraud, S. C., Torn, M. S., Metzger, S., Kumar, J., Arain, M. A., Arkebauer, T. J., Baldocchi, D., Bernacchi, C., Billesbach, D., Black, T. A., Blanken, P. D., Bohrer, G., Bracho, R., Brown, S., Brunsell, N. A., Chen, J., Chen, X., Clark, K., Desai, A. R., Duman, T., Durden, D., Fares, S., Forbrich, I., Gamon, J. A., Gough, C. M., Griffis, T., Helbig, M., Hollinger, D., Humphreys, E., Ikawa, H., Iwata, H., Ju, Y., Knowles, J. F., Knox, S. H., Kobayashi, H., Kolb, T., Law, B., Lee, X., Litvak, M., Liu, H., Munger, J. W., Noormets, A., Novick, K., Oberbauer, S. F., Oechel, W., Oikawa, P., Papuga, S. A., Pendall, E., Prajapati, P., Prueger, J., Quinton, W. L., Richardson, A. D., Russell, E. S., Scott, R. L., Starr, G., Staebler, R., Stoy, P. C., Stuart-Haëntjens, E., Sonntag, O., Sullivan, R. C., Suyker, A., Ueyama, M., Vargas, R., Wood, J. D., and Zona, D.: Representativeness of Eddy-Covariance flux footprints for areas surrounding AmeriFlux sites, *Agricultural and Forest Meteorology*, 301–302, <https://doi.org/10.1016/j.agrformet.2021.108350>, 2021.
- 375 Cowan, N., Levy, P., Tigli, M., Toteva, G., and Drewer, J.: Characterisation of Analytical Uncertainty in Chamber Soil Flux Measurements, *European Journal of Soil Science*, 76, e70 104, <https://doi.org/10.1111/ejss.70104>, 2025.
- 380

Egli, M., Wiesenberg, G., Leifeld, J., Gärtner, H., Seibert, J., Rösli, C., Wingate, V., Dollenmeier, W., Griffel, P., Suremann, J., Weber, J., Zyberaj, M., and Musso, A.: Formation and decay of peat bogs in the vegetable belt of Switzerland, *Swiss Journal of Geosciences*, 114, <https://doi.org/10.1186/s00015-020-00376-0>, 2021.

Emmenegger, L., Leuenberger, M., and Steinbacher, M.: ICOS ATC NRT CO₂ growing time series, Jungfrauoch (13.9 m), 2024-04-01–2025-01-20, 2025.

Eugster, W. and Merbold, L.: Eddy covariance for quantifying trace gas fluxes from soils, *SOIL*, 1, 187–205, <https://doi.org/10.5194/soil-1-187-2015>, 2015.

Ferré, M., Muller, A., Leifeld, J., Bader, C., Müller, M., Engel, S., and Wichmann, S.: Sustainable management of cultivated peatlands in Switzerland: Insights, challenges, and opportunities, *Land Use Policy*, 87, <https://doi.org/10.1016/j.landusepol.2019.05.038>, 2019.

Forbes, E., Benenati, V., Frey, S., Hirsch, M., Koech, G., Lewin, G., Mantas, J. N., and Caylor, K.: Fluxbots: A Method for Building, Deploying, Collecting and Analyzing Data From an Array of Inexpensive, Autonomous Soil Carbon Flux Chambers, *Journal of Geophysical Research: Biogeosciences*, 128, <https://doi.org/10.1029/2023JG007451>, 2023.

Gagnon, S., L'Hérault, E., Lemay, M., and Allard, M.: New low-cost automated system of closed chambers to measure greenhouse gas emissions from the tundra, *Agricultural and Forest Meteorology*, 228–229, 29–41, <https://doi.org/10.1016/j.agrformet.2016.06.012>, 2016.

Görres, C. M., Kammann, C., and Ceulemans, R.: Automation of soil flux chamber measurements: Potentials and pitfalls, *Biogeosciences*, 13, 1949–1966, <https://doi.org/10.5194/bg-13-1949-2016>, 2016.

Healy, R. W., Striegl, R. G., Russell, T. F., Hutchinson, G. L., and Livingston, G. P.: Numerical Evaluation of Static-Chamber Measurements of Soil-Atmosphere Gas Exchange: Identification of Physical Processes, Tech. rep.

Hüppi, R., Felber, R., Krauss, M., Six, J., Leifeld, J., and Fuß, R.: Restricting the nonlinearity parameter in soil greenhouse gas flux calculation for more reliable flux estimates, *PLoS ONE*, 13, <https://doi.org/10.1371/journal.pone.0200876>, 2018.

IPCC: Intergovernmental panel on climate change (IPCC) guidelines for national greenhouse gas inventories. Volume 4. Agriculture, forestry and other land uses., Tech. rep., 2006.

IPCC: 2019 Refinement to the 2006 IPCC Guidelines for National Greenhouse Gas Inventories. Volume 4. Agriculture, forestry and other land uses., Tech. rep., 2019.

IPCC: Summary for policymakers. In *Climate change 2021: The physical science basis. Contribution of Working Group I to the Sixth Assessment Report of the Intergovernmental Panel on Climate Change.*, Tech. rep., 2021.

Jenerette, G. D., Scott, R. L., and Huxman, T. E.: Whole ecosystem metabolic pulses following precipitation events, *Functional Ecology*, 22, 924–930, <https://doi.org/10.1111/j.1365-2435.2008.01450.x>, 2008.

Johannesson, C.-F., Nordén, J., Lange, H., Silvennoinen, H., and Larsen, K.: Optimizing the closure period for improved accuracy of chamber-based greenhouse gas flux estimates, *Agricultural and Forest Meteorology*, 359, 110289, <https://doi.org/10.1016/j.agrformet.2024.110289>, 2024.

Kandel, T. P., Lærke, P. E., and Elsgaard, L.: Effect of chamber enclosure time on soil respiration flux: A comparison of linear and non-linear flux calculation methods, *Atmospheric Environment*, 141, 245–254, <https://doi.org/10.1016/j.atmosenv.2016.06.062>, 2016.

Kobayashi, A. N. A.: alexnaoki/SoilGasFlux: v.0.1.1-alpha Parametric low-cost soil gas flux system, <https://doi.org/10.5281/zenodo.14748701>, 2025.

Lai, D. Y., Roulet, N. T., Humphreys, E. R., Moore, T. R., and Dalva, M.: The effect of atmospheric turbulence and chamber deployment period on autochamber CO₂ and CH₄ flux measurements in an ombrotrophic peatland, *Biogeosciences*, 9, 3305–3322, <https://doi.org/10.5194/bg-9-3305-2012>, 2012.

- Leon, E., Vargas, R., Bullock, S., Lopez, E., Panosso, A. R., and La Scala, N.: Hot spots, hot moments, and spatio-temporal controls on soil
420 CO₂ efflux in a water-limited ecosystem, *Soil Biology and Biochemistry*, 77, 12–21, <https://doi.org/10.1016/j.soilbio.2014.05.029>, 2014.
- MacAgga, R., Asante, M., Sossa, G., Antonijević, D., Dubbert, M., and Hoffmann, M.: Validation and field application of a low-cost device
to measure CO₂ and evapotranspiration (ET) fluxes, *Atmospheric Measurement Techniques*, 17, 1317–1332, <https://doi.org/10.5194/amt-17-1317-2024>, 2024.
- Maier, M., Weber, T. K., Fiedler, J., Fuß, R., Glatzel, S., Huth, V., Jordan, S., Jurasinski, G., Kutzbach, L., Schäfer, K., Weymann, D., and
425 Hagemann, U.: Introduction of a guideline for measurements of greenhouse gas fluxes from soils using non-steady-state chambers, *Journal of Plant Nutrition and Soil Science*, 185, 447–461, <https://doi.org/10.1002/jpln.202200199>, 2022.
- Nickerson, N.: Evaluating Gas Emission Measurements Using Minimum Detectable Flux (MDF), Tech. rep.
- Oertel, C., Matschullat, J., Zurba, K., Zimmermann, F., and Erasmi, S.: Greenhouse gas emissions from soils—A review, <https://doi.org/10.1016/j.chemer.2016.04.002>, 2016.
- 430 Pedersen, A. R., Petersen, S. O., and Schelde, K.: A comprehensive approach to soil-atmosphere trace-gas flux estimation with static chambers, *European Journal of Soil Science*, 61, 888–902, <https://doi.org/10.1111/j.1365-2389.2010.01291.x>, 2010.
- Roeoesli, C. and Egli, M.: Using historical data to access the surface subsidence in the vegetable belt of the Three Lakes Region, Switzerland, *Swiss Journal of Geosciences*, 117, <https://doi.org/10.1186/s00015-024-00452-9>, 2024.
- Schneider, J., Kutzbach, L., Schulz, S., and Wilmdng, M.: Overestimation of CO₂ respiration fluxes by the closed chamber method in low-
435 turbulence nighttime conditions, *Journal of Geophysical Research: Biogeosciences*, 114, <https://doi.org/10.1029/2008JG000909>, 2009.
- Smith, K. A., Ball, T., Conen, F., Dobbie, K. E., Massheder, J., and Rey, A.: Exchange of greenhouse gases between soil and atmosphere: interactions of soil physical factors and biological processes, *European Journal of Soil Science*, 69, 10–20, <https://doi.org/10.1111/ejss.12539>, 2018.
- Venterea, R. T. and Baker, J. M.: Effects of Soil Physical Nonuniformity on Chamber-Based Gas Flux Estimates, *Soil Science Society of*
440 *America Journal*, 72, 1410–1417, <https://doi.org/10.2136/sssaj2008.0019>, 2008.
- Venterea, R. T., Petersen, S. O., De Klein, C. A. M., Pedersen, A. R., Noble, A. D. L., Rees, R. M., Gamble, J. D., and Parkin, T. B.: Global Research Alliance N₂ O Chamber Methodology Guidelines: Flux Calculations, *Journal of Environmental Quality*, 49, 1141–1155, <https://doi.org/10.1002/jeq2.20118>, 2020.
- Zawilski, B. M. and Bustillo, V.: Ultra-low-cost manual soil respiration chamber, *Geoscientific Instrumentation, Methods and Data Systems*,
445 13, 51–62, <https://doi.org/10.5194/gi-13-51-2024>, 2024.